



Date: September 27, 2011
To: All Vendors
From: Diane Ruth

ADDENDUM NO. 1

CONTRACT #2011-08, EXPLOSION PROOF FORCED AIR UNIT HEATERS

Please note that the following information was accidentally omitted from Page 10, Item #A-2:

- Provide four (4) explosion proof forced air unit heaters. Each unit heater shall be 20 KW, **460 Volt, 3 Phase.**

Because of the short notice, we must move the bid opening from 2 pm on Thursday 9/29/11 to **2 pm on Tuesday 10/4/11.**

We apologize for any confusion this may have caused.

If you have any questions concerning this information, please contact me.